



NOTES:

1. THE PLACEMENT OF THE CONCRETE ENCASEMENT NEED NOT BE DONE BY FORMING
2. MIN. THICKNESS OF THE CONCRETE ENCASEMENT TO BE BE 150mm
3. CONCRETE ENCASEMENT TO BE CONTINUOUS FOR DUCTILE IRON PIPE
4. ENCASEMENT ON PVC AND AC SEWERS TO STOP 0.3m EACH WAY OF COUPLING

**CONCRETE ENCASEMENT
DETAIL**

2	City	Drawings revised	02/99
1	Usi	Original drawings created	04/96
No.	By	Revisions	Date

Date: February 12/99	Scale: N.T.S.	Dwg. No. D-11
Drawn by: Bob Smith	Cad file: c:\..\drawings\standard\By_D11	