



INSTALL 50 ϕ G.I. PIPE ON ϕ OF 150 ϕ STANDPIPE WITH PLASTIC CAP 450mm BELOW FINAL GRADE

NOTE:
VALVE AND PIPE ASSEMBLY MAY COME OFF THE SIDE OF THE PIPE AT A 90° ANGLE TO ALLOW FOR A STANDARD THRUST BLOCK AT THE END OF THE CAPPED MAIN. THE PIPE SHOULD BE THREADED TO THE MAIN WITHIN 500mm FROM THE CAPPED END.

UNITS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED

BLOW OFF OR FLUSH VALVE ASSEMBLY DETAIL

2	City	Drawings revised	02/99
1	Usi	Original drawings created	04/96
No.	By	Revisions	Date

Date: February 12/99	Scale: N.T.S	Dwg. No. D-4
Drawn by: Bob Smith	Cad file: c:\..\drawings\standard\By_D4	