



SECTION B-B

NOTES:

1. INDUSTRIAL & COMMERCIAL CROSSINGS REQUIRE 10m BARS 300mm O/C EACH WAY.
2. WHEN INSTALLING CROSSOVER ON EXISTING CURB, GUTTER AND SIDEWALK 10m BARS TO BE DRILLED AND GROUTED INTO EXISTING CONCRETE 300mm O/C.

UNITS ARE IN MILLIMETERS  
UNLESS OTHERWISE NOTED

**SIDEWALK CROSSING FOR  
SIDEWALK SEPARATE  
FROM CURB**

No.	By	Revisions	Date
2	City	Drawings revised	02/99
1	Usi	Original drawings created	04/96

Date: February 12/99	Scale: N.T.S.	Dwg. No. C-4
Drawn by: Bob Smith	Cad file: c:\...\drawings\standard\By_C4	